



February 4, 2021

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 491208

Date: 1/21/21

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	31,161	116	Strand broke mid span. No slip from either dead-end.
			31,035	115	Strand broke mid span. No slip from either dead-end.
		AVERAGE	31,098	116	

Regards,

Scott L. Sanderson  
Senior Quality Engineer

RMB

cc: File 94  
M. Miller