

November 29, 2016

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 238780 Lot No.: 316170 Date: 10/25/16

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8" EHS G.S.*	42,400	43,780	103.2	Strand broke mid span. No slip from either dead-end.
			43,570	102.8	Strand broke mid span. No slip from either dead-end.
		AVERAGE	43,675	103.0	

*Strand is from National Strand

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly