

July 26, 2018


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 460876 Lot No.: 460876 Date: 6/11/18

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8" EHS G.S.	42,400	55,780	131.6	Strand broke mid span. No slip from either dead-end.
			55,430	130.7	Strand broke mid span. No slip from either dead-end.
		AVERAGE	55,605	131.2	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB

cc: File 94
M. Miller