

September 26, 2016


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 231799 Lot No.: 306884-2 Date: 9/2/16

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8" EHS G.S.	42,400	44,590	105.2	Strand broke mid span. No slip from either dead-end.
			44,200	104.2	Strand broke mid span. No slip from either dead-end.
		AVERAGE	44,395	104.7	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly