

November 8, 2016


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 243376 Lot No.: 243376 Date: 10/3/16

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2582	5/16" EHS G.S.	10,200	13,103	128.5	Strand broke mid span. No slip from either dead-end.
			13,118	128.7	Strand broke mid span. No slip from either dead-end.
		AVERAGE	13,111	128.6	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly