

October 23, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 413608

Date: 10/14/19

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|-------------------------|-------------------------|---------------------------|-------------|---|
| BRG-2582 | 5/16" EHS G.S. | 11,200 | 13,414 | 119.8 | One dead-end slipped at max load. No strand failure. |
| | | | 13,547 | 121.0 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 13,481 | 120.4 | |

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller