

October 25, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 414943

Date: 10/24/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2582	5/16" EHS G.S.	11,200	13,184	117.7	One dead-end slipped at max load. No strand failure.
			13,207	117.9	Strand broke at max load. No slip from either dead-end.
		AVERAGE	13,196	117.8	

Regards,



Scott L. Sanderson  
Senior Quality Engineer

RMB  
cc: File 94  
M. Miller