

March 7, 2017

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 259470 Lot No.: 259470 Date: 2/22/17

BRACE-GRIP® Dead-End CAT. NO.	Strand Size* (in.)	Strand RBS* (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2583	3/8" EHS G.S.	15,400	17,385	112.9	Strand broke mid span. No slip from either Dead-End.
			17,323	112.5	Strand broke mid span. No slip from either Dead-End.
		AVERAGE	17,354	112.7	

* Strand is from National Strand

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly