

March 29, 2016


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 196527 Lot No.: 196527 Date: 1/21/16

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2584	7/16" EHS G.S.	20,800	22,722	109.2	Strand broke mid span. No slip occurred.
			22,667	108.9	Strand broke mid span. No slip occurred.
		AVERAGE	22,694	109.1	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly