

October 4, 2018


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 350871 Lot No.: 350871 Date: 9/28/18

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2584	7/16" EHS G.S.	20,800	25,723	123.7	Strand broke mid span. No slip from either dead-end.
			25,652	123.3	Strand broke mid span. No slip from either dead-end.
		AVERAGE	25,688	123.5	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller