

January 18, 2019


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 368041 Lot No.: 368041 Date: 1/11/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	34,374	127.8	Strand broke mid span. No slip from either dead-end.
			34,542	128.4	One dead-end slipped at max load. No strand failure.
			AVERAGE	34,458	128.1

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller