

October 24, 2018


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 352123 Lot No.: 352123 Date: 10/2/18

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|-------------------------|-------------------------|---------------------------|-------------|--|
| BRG-2585 | 1/2" EHS G.S. | 26,900 | 31,132 | 115.7 | Strand broke mid span. No slip from either dead-end. |
| | | | 31,195 | 115.9 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 31,164 | 115.8 | |

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller