

January 2, 2020

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 422474

Date: 12/10/19

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|-------------------------|-------------------------|---------------------------|-------------|--|
| BRG-2585 | 1/2" EHS G.S. | 26,900 | 31,358 | 117 | Strand broke mid span. No slip from either dead-end. |
| | | | 31,471 | 117 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 31,415 | 117 | |

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller