

July 11, 2019


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 388346 Lot No.: 388346 Date: 7/2/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	33,324	123.9	One Dead-End broke at the loop at max load. No slip or strand failure.
			33,025	122.8	One Dead-End broke at the loop at max load. No slip or strand failure.
		AVERAGE	33,175	123.3	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller