

August 31, 2016


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 230554    Lot No.: 230554    Date: 8/29/16

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	31,178	115.9	Strand broke mid span. No slip from either dead-end.
			31,319	116.4	Strand broke mid span. No slip from either dead-end.
		AVERAGE	31,249	116.2	

Regards,



Scott L. Sanderson  
Senior Quality Engineer

RMB  
cc: File 94  
J. Reilly