

November 19, 2018


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 358793 Lot No.: 358793 Date: 11/12/18

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	31,461	117.0	Strand broke mid span. No slip from either dead-end.
			31,509	117.1	Strand broke mid span. No slip from either dead-end.
		AVERAGE	31,485	117.1	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller