

December 15, 2015

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fittings to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.:	184302	Lot No.:	184302	Date:	10/5/15
BRACE-GRIP® DE CAT NO.	STRAND SIZE (in.)	STRAND RBS (lbs.)	MAXIMUM LOAD (lbs.)	% RBS	FAILURE MODE AT MAX. LOAD
			7,483	112.5	Strand broke mid span; no slip.
BRG-2580	1/4" EHS G.S.	6,650	7,498	112.8	Strand broke mid span; no slip.
AVERAGE			7,491	112.7	

Regards,

Scott L. Sanderson

Corporate Quality Assurance Engineer

ma

cc: File 94
J. Reilly