

March 29, 2016


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 174074 Lot No.: 174074 Date: 7/13/15

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	7,471	112.3	Strand broke near a dead-end. No slip occurred.
			7,443	111.9	Strand broke near a dead-end. No slip occurred.
		AVERAGE	7,457	112.1	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly