

March 29, 2016


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 183319 Lot No.: 183319 Date: 9/22/15

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	30,942	115.0	Strand broke mid span. No slip occurred.
			30,917	114.9	Strand broke mid span. No slip occurred.
		AVERAGE	30,929	115.0	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly