

September 6, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 9127

Date: 7/16/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580B	1/4" EHS G.S.	6,650	7,456	112.1	Strand broke mid span. No slip from either dead-end.
			7,487	112.6	Strand broke mid span. No slip from either dead-end.
		AVERAGE	7,471.5	112.4	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller