

January 4, 2019


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 358781 Lot No.: 358781 Date: 1/4/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	8,581	129.0	Strand broke mid span. No slip from either dead-end.
			8,566	128.8	Strand broke mid span. No slip from either dead-end.
		AVERAGE	8,574	128.9	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller