

September 5, 2018


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 347880    Lot No.: 347880    Date: 8/28/18

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	8,431	126.8	Strand broke mid span. No slip from either dead-end.
			8,480	127.5	Strand broke mid span. No slip from either dead-end.
		AVERAGE	8,456	127.2	

Regards,



Scott L. Sanderson  
Senior Quality Engineer

RMB  
cc: File 94  
M. Miller