

September 18, 2017


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 290907    Lot No.: 290907    Date: 8/31/17

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	8,153	122.6	Strand broke mid span. No slip from either dead-end.
			8,076	121.4	Strand broke mid span. No slip from either dead-end.
		AVERAGE	8,115	121.9	

Regards,



Scott L. Sanderson  
Senior Quality Engineer

RMB

cc: File 94  
J. Reilly