



November 8, 2021

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 228029

Date: 10/28/21

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8" EHS G.S.	42,400	47,940	113	Strand broke mid span. No slip from either dead- end.
			48,070	113	Strand broke mid span. No slip from either dead- end.
	AVERAGE	48,005	113		

Regards,

Scott L. Sanderson

Senior Quality Engineer

RMB

cc: File 94, M. Miller

PLP.COM