



October 26, 2022

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 250893

Date: 9/20/22

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8"	42,400	47,300	112	Strand broke mid span. No slip from either dead- end.
	EHS G.S.		47,620	112	Strand broke mid span. No slip from either dead- end.
		AVERAGE	47,460	112	

Regards,

Scott L. Sanderson

Senior Quality Engineer

RMB

cc: File 94, M. Miller

PLP.COM