



October 19, 2022

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 577556

Date: 10/7/22

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|----------------------|----------------------|------------------------|-------------|---|
| BRG-2582 | 5/16" EHS G.S. | 11,200 | 13,289 | 119 | Strand broke mid span. No slip from either dead- end. |
| | | | 13,285 | 119 | Strand broke mid span. No slip from either dead- end. |
| | AVERAGE | 13,287 | 119 | | |

Regards,

Scott L. Sanderson

Senior Quality Engineer

RMB

cc: File 94, M. Miller

PLP.COM