

October 25, 2021

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 529817

Date: 10/22/21

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2583	3/8" EHS G.S.	15,400	16,633	108	Strand broke mid span. No slip from either dead-end.
			16,627	108	Strand broke mid span. No slip from either dead-end.
		AVERAGE	16,630	108	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB

cc: File 94
M. Miller