

October 29, 2021

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 530387

Date: 10/7/21

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	182" EHS G.S.	26,900	31,029	117	Strand broke mid span. No slip from either dead-end.
			31,147	118	Strand broke mid span. No slip from either dead-end.
		AVERAGE	31,088	117	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller