

March 5, 2020

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 240598

Date: 2/27/20

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8" EHS G.S.	42,400	49,730	117	Strand broke mid span. No slip from either dead-end.
			49,410	117	Strand broke mid span. No slip from either dead-end.
		AVERAGE	49,570	117	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller