

August 29, 2017

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 600602 Lot No.: 600602 Date: 7/25/17

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-1587	5/8" EHS G.S.*	42,400	53,470	126.1	Strand Broke mid span. No slip from either dead-end.
			53,680	126.6	Strand Broke mid span. No slip from either dead-end.
		AVERAGE	53,575	126.3	

* = Strand is from WireCo.

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
J. Reilly