

July 12, 2019


Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 367723 Lot No.: 367723 Date: 1/10/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2582	5/16" EHS G.S.	11,200	13,373	119.4	One Dead-End slipped at max load. No strand failure.
			13,007	116.1	One Dead-End slipped at max load. No strand failure.
		AVERAGE	13,190	117.8	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller