

June 17, 2020

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 454046

Date: 6/10/20

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|-------------------------|-------------------------|---------------------------|-------------|--|
| BRG-2583 | 3/8" EHS G.S. | 15,400 | 17,297 | 112 | Strand broke mid span. No slip from either dead-end. |
| | | | 17,258 | 112 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 17,278 | 112 | |

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller