

September 9, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 9135

Date: 7/26/19

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|-------------------------|-------------------------|---------------------------|-------------|--|
| BRG-2583 | 3/8" EHS G.S. | 15,400 | 17,355 | 112.7 | Strand broke mid span. No slip from either dead-end. |

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB

cc: File 94
M. Miller