

September 6, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 9156

Date: 7/16/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2584	7/16" EHS G.S.	20,800	23,783	114.3	Loop of one dead-end broke at max load. No slip from either dead-end.
			23,947	115.1	Strand broke mid span. No slip from either dead-end.
		AVERAGE	23,865	114.7	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller