

March 7, 2017

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Work Order No.: 258655    Lot No.: 258655    Date: 2/22/17

BRACE-GRIP® Dead-End CAT. NO.	Strand Size* (in.)	Strand RBS* (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	30,938	115.0	Strand broke mid span. No slip from either Dead-End.
			31,042	115.4	Strand broke mid span. No slip from either Dead-End.
		AVERAGE	30,990	115.2	

\* Strand is from National Strand

Regards,



Scott L. Sanderson  
Senior Quality Engineer

RMB  
cc: File 94  
J. Reilly