

March 18, 2020

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 427819

Date: 3/10/20

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|-------------------------|-------------------------|---------------------------|-------------|--|
| BRG-2580 | 1/4" EHS G.S. | 6,650 | 8,444 | 127 | Strand broke mid span. No slip from either dead-end. |
| | | | 8,398 | 126 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 8,421 | 127 | |

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller