

December 16, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 421668

Date: 12/16/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	8,346	126	Strand broke mid span. No slip from either dead-end.
			8,382	126	Strand broke near the end of one dead end. No slip from either dead-end.
		AVERAGE	8,364	126	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB

cc: File 94
M. Miller