

October 23, 2019

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 413606

Date: 10/10/19

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	8,464	127.3	Strand broke mid span. No slip from either dead-end.
			8,503	127.9	Strand broke mid span. No slip from either dead-end.
		AVERAGE	8,484	127.6	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller