

April 12, 2021

Testing was performed in accordance with:


ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 492898

Date: 3/30/21

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2585	1/2" EHS G.S.	26,900	29,987	111	At max load, 1 wire broke in the loop of the dead-end, causing the sample to slip.
			30,472	113	At max load, 1 wire broke in the loop of the dead-end, causing the sample to slip.
		AVERAGE	30,230	112	

Regards,



Scott L. Sanderson
Senior Quality Engineer

RMB
cc: File 94
M. Miller