



March 29, 2022

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 546279

Date: 3/4/22

BRACE-GRIP® Dead-End CAT. NO.	Strand Size (in.)	Strand RBS (lbs.)	Maximum Load (lbs.)	% of RBS	Failure Mode at Maximum Load
BRG-2580	1/4" EHS G.S.	6,650	7,866	118	Strand broke mid span. No slip from either dead- end.
			7,822	118	Strand broke mid span. No slip from either dead- end.
	AVERAGE	7,844			

Regards,

Scott L. Sanderson

Senior Quality Engineer

RMB

cc: File 94, M. Miller

PLP.COM